

Tech Manual Excerpt

System Design

Membrane System Design Guidelines for Midsize FilmTec™ Elements

Membrane System
Design Guidelines
for Midsize
FilmTec™
Elements

The following tables show the recommended guidelines for designing RO systems with 2.5 and 4-inch FilmTec™ Elements in light industrial, small commercial, and institutional applications, or for piloting large systems.

Light industrial systems in Table 1 have the same requirements as for large systems, requiring stable performance over several years. They are sometimes used for piloting large systems with continuous operation, CIP facilities and no (or minimal) concentrate recirculation. The expected membrane lifetime is more than 3 years.

Table 1: Design guidelines for FilmTec™ Elements in light industrial and small seawater applications

	RO	Well	Softened		Wastewater (filtered tertiary			
Feed Source	Permeate	Water	Municipal	Surface	effluent)		Seawater Well	
					MF ¹	Conventional	or MF ¹	Open Intake
Feed Silt Density Index (%/min)	SDI <1	SDI < 3	SDI < 3	SDI < 5	SDI < 3	SDI < 5	SDI < 3	SDI < 5
Typical Target Flux, gfd (L/m²h)	22 (37)	18 (30)	16 (27)	14 (24)	13 (22)	11 (19)	13 (22)	11 (19)
Maximum Element Recovery (%)	30	19	17	15	14	12	15	13
Element Diameter	Maximum Permeate Flowrate, gpd (m³/d)							
2.5-inch	800 (3.0)	700 (2.6)	600 (2.3)	500 (1.9)	500 (1.9)	400 (1.5)	700 (2.6)	600 (2.3)
4.0-inch (except fullfits and LC products)	2,200 (8.4)	1,800 (6.8)	1,600 (6.0)	1,400 (5.4)	1,300 (4.8)	1,100 (4.1)	1,600 (6.0)	1,500 (5.7)
4.0-inch diameter (LC products)	2,600 (10.1)	2,100 (8.2)	1,900 (7.2)	1,700 (6.5)	1,500 (5.7)	1,300 (5.0)	-	-
Fullfit 4040	2,500 (9.7)	2,000 (7.8)	1,800 (6.9)	1,600 (6.2)	1,400 (5.5)	1,300 (5.0)	-	-
Element Type	Minimum Concentrate Flowrate, gpm (m³/h)¹							
2.5-inch diameter	0.7 (0.16)	1 (0.2)	1 (0.2)	1 (0.2)	1 (0.2)	1 (0.2)	1 (0.2)	1 (0.2)
4.0-inch diameter (except fullfits)	2 (0.5)	3 (0.7)	3 (0.7)	3 (0.7)	4 (0.9)	5 (1.1)	3 (0.7)	4 (0.9)
Fullfit 4040	6 (1.4)	6 (1.4)	6 (1.4)	6 (1.4)	6 (1.4)	6 (1.4)	NA	NA

Membrane System
Design Guidelines
for Midsize
FilmTec[™]
Elements (cont.)

Element Type	Maximum Feed Flowrate gpm (m³/h)	Maximum Pressure Drop per Element psig (bar)	Maximum Feed Pressure psig (bar)
Tape-wrapped 2540	6 (1.4)	13 (0.9)	600 (41)
Fiberglassed 2540	6 (1.4)	15 (1.0)	600 (41)
Seawater 2540	6 (1.4)	13 (0.9)	1,000 (69)
Tape-wrapped 4040	14 (3.2)	13 (0.9)	600 (41)
Fiberglassed 4040	16 (3.6)	15 (1.0)	600 (41)
Seawater Fiberglassed 4040	16 (3.6)	15 (1.0)	1,000 (69)
Fullfit 4040	18 (4.1)	15 (1.0)	600 (41)

 $^{^{1}}$ MF: Microfiltration - continuous filtration process using a membrane with pore size of < 0.5 micron.

In Table 2, the small commercial systems typically contain 1 – 6 elements that are either regularly replaced or cleaned (every half year or year) or performance loss is acceptable. The expected element lifetime is not more than 3 years. This is a low-cost, compact solution for intermittently operated systems.

Table 2: Design guidelines for FilmTec™ Elements in small commercial applications

Feed Source	RO Permeate	Softened Municipal	Well Water	Surface or Municipal Water
Feed Silt Density Index (%/min)	SDI < 1	SDI < 3	SDI < 3	SDI < 5
Typical Target Flux, gfd (L/m²h)	30 (51)	30 (51)	25 (42)	20 (34)
Maximum Element Recovery (%)	30	30	25	20
Maximum Permeate Flowrate, gpd (m³/d)				
2.5-inch diameter	1,100 (4.2)	1,100 (4.2)	900 (3.4)	700 (2.7)
4.0-inch diameter	3,100 (11.7)	3,100 (11.7)	2,600 (9.8)	2,100 (7.9)
Minimum Concentrate Flowrate ¹ , gpm (m ³ /h)				
2.5-inch diameter	0.5 (0.11)	0.5 (0.11)	0.7 (0.16)	0.7 (0.16)
4.0-inch diameter	2 (0.5)	2 (0.5)	3 (0.7)	3 (0.7)

² We recommend that the pressure drop for new/clean elements be at least 20% below the maximum.

ote: The limiting values listed above have been incorporated into the WAVE software. Designs of systems in excess of the guidelines results in a warning on the WAVE report.

Membrane System
Design Guidelines
for Midsize
FilmTec™
Elements (cont.)

Element Type	Maximum Feed Flowrate U.S. gpm (m³/h)	Maximum Pressure Drop per Element ¹ psig (bar)	Maximum Feed Pressure psig (bar)
Tape-wrapped 2540	6 (1.4)	13 (0.9)	600 (41)
Fiberglased 2540	6 (1.4)	15 (1.0)	600 (41)
Seawater 2540	6 (1.4)	13 (0.9)	1,000 (69)
Tape-wrapped 4040	14 (3.2)	13 (0.9)	600 (41)
Fiberglassed 4040	16 (3.6)	15 (1.0)	600 (41)
Seawater 4040	16 (3.6)	15 (1.0)	1,000 (69)

 1 We recommend that the pressure drop for new/clean elements be at least 20% below the maximum.

Note: The limiting values listed above have been incorporated into the WAVE software. Designs of systems in excess of the guidelines results in a warning on the WAVE report.

Excerpt from FilmTec™ Reverse Osmosis Membranes Technical Manual (Form No. 45-D01504-en), Chapter 3, "System Design."

Have a question? Contact us at:

www.dupont.com/water/contact-us

All information set forth herein is for informational purposes only. This information is general information and may differ from that based on actual conditions. Customer is responsible for determining whether products and the information in this document are appropriate for Customer's use and for ensuring that Customer's workplace and disposal practices are in compliance with applicable laws and other government enactments. The product shown in this literature may not be available for sale and/or available in all geographies where DuPont is represented. The claims made may not have been approved for use in all countries. Please note that physical properties may vary depending on certain conditions and while operating conditions stated in this document are intended to lengthen product lifespan and/or improve product performance, it will ultimately depend on actual circumstances and is in no event a guarantee of achieving any specific results. DuPont assumes no obligation or liability for the information in this document. References to "DuPont" or the "Company" mean the DuPont legal entity selling the products to Customer unless otherwise expressly noted. NO WARRANTIES ARE GIVEN; ALL IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE ARE EXPRESSLY EXCLUDED. No freedom from infringement of any patent or trademark owned by DuPont or others is to be inferred.

DuPont™, the DuPont Oval Logo, and all trademarks and service marks denoted with ™, ^{sм} or ® are owned by affiliates of DuPont de Nemours Inc. unless otherwise noted. © 2020 DuPont.

